Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated :07/07/2026

It is certified that an inspection team headed by AJEET KUMAR SINGH, JUNIOR ENGINEER (Name of Officer with Designation) From U.P. JAIL NIGAM (RURAL) BASTI (Name of Department/ Office) inspected the LITTLE FLOWERS SCHOOL, Pura Babhanan, Basti (Name & Address of the School) on 30.06.2026 (Date of Inspection) and on the basis of Water test Report (Attached) bearing No 204 dated 07.07.2026 of District Level Water Analysis Laboratory, U.P Jal Nigam (Rural), Basti (PHED Lab) certified that the LITTLE FLOWERS SCHOOL (Name of the School) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 1 Year.

इं० अजीत कुमार सिंह (जू०इं०)
खण्ड कार्यालय उ०प्र० जल निगम (ग्रामीण)

Signature with Seal :

Name : AJEET KUMAR SINGH

Designation : JUNIOR ENGINEER

Name & Address of the office / Department: U.P.J.N(R)

To,

LITTLE FLOWERS SCHOOL

Pura Babhanan

Basti

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Analysis Report

District Level Water Analysis Laboratory , U.P Jal Nigam (Rural), BASTI

UPJN CONSTRUCTION DIVISION NEAR ST BASIL'S SCHOOL, KHEERIGHAT, BASTI

Rept No.1	Chemical Test /DWTL				
ULR No.	T642420260000000020	Date	7/7/2026	S.No.	204

Customer Details:LITTLE FLOWERS SCHOOL

Office Name and Address of the customer: PURA BABHNAN, BASTI

Ref Letter No & Date

Basic details of sample

District	BASTI	Block	GAUR
Gram Panchayat	PURA PAIKOLIYA	Village	PURA PAIKOLIYA
Habitation	PURA	Location	PURA BABHNAN
Water Source	RO	Sample No.	LFS/306
Quantity of Sample	1000ml	Date of Collection	30/06/2026
Receiving Date	30/06/2026	Sample Collector	AMBARISH
Sample Depositer	AMBARISH		
Analysis Start Date	30/06/2026	Analysis Completion Date	31/06/2026

Environmental Condition

Temperature	25±2°C	Relative Humidity	Upto 70%

Technical Data of Analysis

S.No.		Units	Observed Value	Specified Values as		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	pH	-	7.66	6.5-8.5	6.5-8.5	IS 3025 (Part 11):2022
2	Turbidity	(NTU)	0.49	1	5	IS 3025 (Part 10):2023
3	TDS	(mg/L)	198	500	2000	IS 3025 (Part 16):2023
4	Chloride	(mg/L)	8	250	1000	APHA 24 Edition- 4500-Cl, Method-B-(Argentometric Method):2023
5	Total Alkalinity	(mg/L)	12	200	600	IS 3025 (Part 23):2023
6	Fluoride	(mg/L)	0.049	1	1.5	APHA 24 Edition 4500-F, Method-C (Electrode Method):2023

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.
5. BDL:Below Detection Limit

Prepared By

(ANKIT KUMAR)

Lab Technician

Authorized Signatory

District Level Water Analysis Laboratory Quality Manager UPJN

(MAHIMA TRIPATHI)

Technical Manager

.....REPORT .....

Analysis Report

District Level Water Analysis Laboratory , U.P Jal Nigam (Rural), BASTI

UPJN CONSTRUCTION DIVISION NEAR ST BASIL'S SCHOOL, KHEERIGHAT, BASTI

Rept No.1	Chemical Test /DWTL	Date	7/7/2026	S.No.	204	1
ULR No.						

Customer Details:LITTLE FLOWERS SCHOOL

Office Name and Address of the customer: PURA BABHNAN, BASTI

Ref Letter No & Date

Basic details of sample

District	BASTI	Block	GAUR
Gram Panchayat	NA	Village	PURA PAIKOLIYA
Habitation	NA	Location	PURA BABHNAN
Water Source	RO	Sample No.	LFS/306
Quantity of Sample	200 ml	Date of Collection	30/06/2026
Receiving Date	30/06/2026	Sample Collector	AMBARISH
Sample Depositer	AMBARISH		
Analysis Start Date	30/06/2026	Analysis Completion Date	1/7/2026

Environmental Condition

Temperature	25±2°C	Relative Humidity	Upto 70%

Technical Data of Analysis

S.No.		Units	Observed Value	Specified Values as		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
			A			
1	2	3	4	5	6	7
1	TOTAL COLIFORM/ E. coli	-	ABSENT	SHOULD BE ABSENT IN 100 ml SAMPLE		MPN/MFT METHOD

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

5.BDL:Below Detection Limit

Prepared By

(UPASANA CHANDRA)
Lab Technician

District Level Water Analysis Laboratory

Authorized Signatory

(MAHIMA TRIPATHI
Technical Manager

Manager